Ref. Certif. No.

DE 2-047467

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Connector
Name and address of the applicant	KUPO Technology Co., Ltd. B66,No.2050 Dingsheng Road, 201616 Shanghai, P.R. China
Name and address of the manufacturer	KUPO Technology Co., Ltd. B66,No.2050 Dingsheng Road, 201616 Shanghai, P.R. China
Name and address of the factory Note: *When more than one factory, please report on page 2*	TAIZHOU UNISON ENTERTAINMENT TECHNOLOGY CO.,LTD No. 3 Yongfeng Road, High-Tech Industrial Park, Gaogang District, Taizhou City, 225300 Jiangsu, P.R. China
Ratings and principal characteristics	1000V AC/DC; IP67(after mounted and engaged) 400A for PFLS-a-S120M40A, PFLD-a-S120M40A, PFPS-a, PFPD-a 500A for PFLS-a-S150M40A, PFLD-a-S150M40A, PFPS-a-T5, PFPD-a-T5 (See test report for futher ratings)
Trademark / Brand (if any)	KUPO
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	PFLS-a-S120M40A, PFLD-a-S120M40A, PFPS-a, PFPD-a PFLS-a-S150M40A, PFLD-a-S150M40A, PFPS-a-T5, PFPD-a-T5 (a=1BN, 2BK, 3GY, NBL, EGN, 1R, 2W, 3BL, NBK, 2O, 3Y, NGY, 1BK, 2R, 2Y, NW)
Additional information (if necessary may also be reported on page 2)	See test report
A sample of the product was tested and found to be in conformity with	IEC 61984:2008
As shown in the Test Report Ref. No. which forms part of this Certificate	CN26B89B 001

This CB Test Certificate is issued by the National Certification Body

TÜVRheinland®

TÜV Rheinland LGA Products GmbH
Tillystr. 2, 90431 Nürnberg, Germany
Mail: cert-validity@de.tuv.com

Date: 2026-08-26

Signature: Paulus Hou

10/061SMD 2024-12 rke-simplified

Disclaimer: This is an electronically released document. The authenticity can be verified on the IECEE Website "http://certificates.iecee.org" (1.3s / 0)